



Client ID: Village of Wauconda Water Department

Report Date: January 25, 2010

Project Name: Non Compliance Volatile Organic Compounds

Lab Order: 10010401

Client Sample ID: WL00639

- WELL #6

Matrix: DRINKING WATER

Lab ID: 10010401-01

Date Received: 01/13/2010 3:45 PM

Collection Date: 01/13/2010 8:15 AM

Parameter	Result	Qual.	Report Limit	MCL	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev4.1,1995			Analyst: LS		
Benzene	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
Carbon tetrachloride	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
Chlorobenzene	ND		0.500	100	µg/L	1	01/16/2010 10:00 PM	R87681
1,4-Dichlorobenzene	ND		0.500	75	µg/L	1	01/16/2010 10:00 PM	R87681
1,2-Dichlorobenzene	ND		0.500	600	µg/L	1	01/16/2010 10:00 PM	R87681
1,2-Dichloroethane	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
1,1-Dichloroethene	ND		0.500	7	µg/L	1	01/16/2010 10:00 PM	R87681
cis-1,2-Dichloroethene	ND		0.500	70	µg/L	1	01/16/2010 10:00 PM	R87681
trans-1,2-Dichloroethene	ND		0.500	100	µg/L	1	01/16/2010 10:00 PM	R87681
1,2-Dichloropropane	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
Ethylbenzene	ND		0.500	700	µg/L	1	01/16/2010 10:00 PM	R87681
Methylene chloride	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
Styrene	ND		0.500	100	µg/L	1	01/16/2010 10:00 PM	R87681
Tetrachloroethene	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
Toluene	ND		0.500	1000	µg/L	1	01/16/2010 10:00 PM	R87681
1,2,4-Trichlorobenzene	ND		0.500	70	µg/L	1	01/16/2010 10:00 PM	R87681
Trichloroethene	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
1,1,1-Trichloroethane	ND		0.500	200	µg/L	1	01/16/2010 10:00 PM	R87681
1,1,2-Trichloroethane	ND		0.500	5	µg/L	1	01/16/2010 10:00 PM	R87681
Vinyl chloride	ND		0.500	2	µg/L	1	01/16/2010 10:00 PM	R87681
Total Xylenes	ND		0.500	10000	µg/L	1	01/16/2010 10:00 PM	R87681
Surrogate: 1,2-Dichlorobenzene-d4	94.6		66.8 - 122		%REC	1	01/16/2010 10:00 PM	R87681
Surrogate: 4-Bromofluorobenzene	96.2		67.7 - 120		%REC	1	01/16/2010 10:00 PM	R87681
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev4.1,1995			Analyst: LS		
Methyl tert-butyl ether	ND		0.500		µg/L	1	01/16/2010 10:00 PM	R87681

Qualifiers:

Base Report MCL-
Continued 2004

- * Value exceeds Maximum Contaminant Level
- c Analyte not included in SLI scope of accreditation
- G Refer to case narrative page for specific comments
- J Analyte detected below quantitation limit (QL)
- ND Not Detected at the SLI Reporting Limit

- B Analyte detected in the associated Method Blank
- E Estimated, analyte detected above quantitation range
- H Holding times for preparation or analysis exceeded
- NA Not Applicable
- Q Internal standard recovery is outside SLI in-house criteria (no method specific requirements exist)