



Client ID: Village of Wauconda Water Department

Report Date: April 19, 2010

Project Name: Non Compliance Volatile Organic Compounds

Lab Order: 1004102

Client Sample ID: WL01520 - WELL #9

Matrix: DRINKING WATER

Lab ID: 1004102-005 Date Received: 04/05/2010 3:35 PM

Collection Date: 04/05/2010 10:00 AM

Parameter	Result	MCL	Report Limit	Qual.	Units	Dilution Factor	Date Analyzed	Batch ID
VOLATILE ORGANIC COMPOUNDS (REGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: ap		
Benzene	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Carbon tetrachloride	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Chlorobenzene	ND	100	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,4-Dichlorobenzene	ND	75.0	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,2-Dichlorobenzene	ND	600	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,2-Dichloroethane	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,1-Dichloroethene	ND	7.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
cis-1,2-Dichloroethene	ND	70.0	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
trans-1,2-Dichloroethene	ND	100	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,2-Dichloropropane	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Ethylbenzene	ND	700	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Methylene chloride	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Styrene	ND	100	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Tetrachloroethene	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Toluene	ND	1,000	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,2,4-Trichlorobenzene	ND	70.0	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Trichloroethene	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,1,1-Trichloroethane	ND	200	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
1,1,2-Trichloroethane	ND	5.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Vinyl chloride	ND	2.00	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Total Xylenes	ND	10,000	0.500		µg/L	1	04/14/2010 3:58 PM	R1175
Surr: 1,2-Dichlorobenzene-d4	103	0	66.8-122		%REC	1	04/14/2010 3:58 PM	R1175
Surr: 4-Bromofluorobenzene	103	0	67.7-120		%REC	1	04/14/2010 3:58 PM	R1175
VOLATILE ORGANIC COMPOUNDS (UNREGULATED)			Method: EPA-524.2-Rev 4.1, 1995			Analyst: ap		
Methyl tert-butyl ether	ND	0	0.500		µg/L	1	04/14/2010 3:58 PM	R1175

- Qualifiers:**
- * Value exceeds Maximum Contaminant Level
 - c Analyte not in SLI scope of accreditation
 - G Refer to case narrative page for specific comments
 - J Analyte detected below quantitation limit (QL)
 - ND Not Detected at the Reporting Limit
 - B Analyte detected in the associated Method Blank
 - E Estimated, detected above quantitation range
 - H Holding times for preparation or analysis exceeded
 - N Tentatively identified compounds
 - R RPD outside accepted recovery limits